

YOUR COMPANY NAME

DESCRIPTION OF WORK	
JOB REFERENCE	
PRINCIPAL CONTRACTOR / CLIENT	
SITE ADDRESS	
REFERENCE 005	ELECTRICITY AND OTHER SERVICES ON SITE

PERSONS AT RISK – E = EMPLOYEE, SE = SITE EMPLOYEES, P = PUBLIC

LIKLIHOOD OF INJURY – H = HIGH, M = MEDIUM, L = LOW

Risk	Persons At Risk			Likelihood of Injury			Control Measures	Likelihood of Injury With Control Measures		
	E	SE	P	H	M	L		H	M	L
Electrocution, death, serious injury, shock and fire							Trained persons only to use equipment			
							Provide safe and suitable equipment – 110v portable equipment with transformers or RCD's on equipment with higher voltage			
							All equipment to be checked and PAT tested on a regular basis			
							Keep all trailing leads tidy and not leave trip hazards			
							Unplug equipment when not being used			
							Replace any defective equipment or cables			
							Identify location of services before work starts			
							Turn off power or use effective warning signs or protective barriers			
Gas leakage leading to explosions							Consider the use of Permit to Work systems were they have been identified as a safe system of work			
							Identify services before starting work			
							Put up warning signs indicating type service			
							Barrier off work whilst working in the vicinity			
						Protect pipes from damage or hot works				

						Do not use equipment outside of manufactures instructions for use			
--	--	--	--	--	--	--	--	--	--