

# YOUR COMPANY NAME

DESCRIPTION OF WORK	
JOB REFERENCE	
PRINCIPAL CONTRACTOR / CLIENT	
SITE ADDRESS	
HAZARD REFERENCE 016	MATERIAL HANDLING – USING A GENIE LIFT

PERSONS AT RISK – E = EMPLOYEE, SE = SITE EMPLOYEES, P = PUBLIC  
 LIKLIHOOD OF INJURY – H = HIGH, M = MEDIUM, L = LOW

Risk	Persons At Risk			Likelihood of Injury			Control Measures	Likelihood of Injury With Control Measures		
	E	SE	P	H	M	L		H	M	L
Equipment failing under load							Check equipment is capable of lifting the load required. SWL should be identified on the equipment. Check inspection sheet with delivery.			
Materials falling off equipment							Always operate the equipment from a position of safety (see manufacturers instructions) Use appropriate associated equipment i.e. slings, lifting tackle, ratchet lashings, fork extensions Never leave a load suspended or unattended Never attempt to move a load with it raised at height			
Genie lift falling over							Always ensure that wheels are locked in position Always operate the equipment on firm level ground Never operate the equipment if there is obvious signs of damage			
Persons being trapped							Personnel must never ride on equipment			

Persons being electrocuted							Never operate the equipment close to any overhead power lines			
----------------------------	--	--	--	--	--	--	---	--	--	--