

**YOUR COMPANY NAME**

<b>DESCRIPTION OF WORK</b>	
<b>JOB REFERENCE</b>	
<b>PRINCIPAL CONTRACTOR / CLIENT</b>	
<b>SITE ADDRESS</b>	
<b>HAZARD REFERENCE 024</b>	<b>WORKING AT HEIGHT – OPERATION OF TOWER HOISTS</b>

**PERSONS AT RISK – E = EMPLOYEE, SE = SITE EMPLOYEES, P = PUBLIC**  
**LIKLIHOOD OF INJURY – H = HIGH, M = MEDIUM, L = LOW**

Risk	Persons At Risk			Likelihood of Injury			Control Measures	Likelihood of Injury With Control Measures		
	E	SE	P	H	M	L		H	M	L
Serious injury, death or entrapment when operating							Only trained operatives to operate			
							Check that equipment is in date regarding its statutory tests and inspections.			
							Operative to control the hoist from one position having unrestricted view of the platform throughout			
							Do not exceed the safe working load (SWL) displayed on the hoist			
							All loads must be secure and stable so as not to move during while hoist is in motion			
							All loose items to be kept in a secure container or other form of restraint while being carried on the platform			
							No persons are to travel on the material hoist			
							All gates to be kept closed at ground level and at all landings when the platform is in operation			
							Landing gates to be kept free of obstructions from materials and plant			
							No unauthorised person to operate or interfere with the hoist			

								Any defects are to be reported immediately			
--	--	--	--	--	--	--	--	--	--	--	--