

YOUR COMPANY NAME

DESCRIPTION OF WORK	
JOB REFERENCE	
PRINCIPAL CONTRACTOR / CLIENT	
SITE ADDRESS	
HAZARD REFERENCE 028	WORKING AT HEIGHT – SCAFFOLDING (SUPPLIED BY MAIN CONTRACTOR)

PERSONS AT RISK – E = EMPLOYEE, SE = SITE EMPLOYEES, P = PUBLIC
LIKLIHOOD OF INJURY – H = HIGH, M = MEDIUM, L = LOW

Risk	Persons At Risk			Likelihood of Injury			Control Measures	Likelihood of Injury With Control Measures		
	E	SE	P	H	M	L		H	M	L
Serious Injury or death falling from height or collapse of scaffold.							Make sure scaffold has been erected by qualified scaffold erectors			
							Do not exceed the safe working load (SWL) of displayed on the scaffold tag certificate			
							All loads to be secure so as not to move whilst on the platform			
							Do not use scaffold if it is incomplete. Do not ignore 'Scaffold Incomplete' warning signs			
							All scaffolds to have toe boards and guardrails and to stop loose items falling. Report if any missing			
							Only use recognised access systems to reach working platforms			
							All boards to be secure and in place. Report if any are loose or missing			
							Amendments to scaffolding to be made by qualified scaffolder. All requests to be made to main contractor			
							Poor quality or condition of scaffold is to be reported and identified to main contractor. Do not use until it has been passed by a competent person			
							Cease work during extreme wind speeds			