

YOUR COMPANY NAME

DESCRIPTION OF WORK	
JOB REFERENCE	
PRINCIPAL CONTRACTOR / CLIENT	
SITE ADDRESS	
HAZARD REFERENCE 017	UNDERGROUND SERVICES

PERSONS AT RISK – E = EMPLOYEE, SE = SITE EMPLOYEES, P = PUBLIC
LIKLIHOOD OF INJURY – H = HIGH, M = MEDIUM, L = LOW

Risk	Persons At Risk			Likelihood of Injury			Control Measures	Likelihood of Injury With Control Measures		
	E	SE	P	H	M	L		H	M	L
Electrocution, gas explosion leading to death, serious injury							Identify all underground services prior to work taking place			
							Treat a unidentified service pipes, cables or ducts as live until notified otherwise			
							Expose and excavate around any services with hand-tools (not picks). No plant or machines to be used within 500mm of service.			
							Have in place emergency procedures should the services become broken or damaged			
							Check all services on a regular basis for damage			
							Support any service with temporary devices/equipment until it can be secured or supported permanently			
							Have in place a safe system of work (Permit to Work)			
							Use appropriate tools/equipment to undertake work local to the services.			